



Establishment of the national training center for nearly Zero Energy Buildings (nZEB)



Energy Institute Hrvoje Požar

Structure and timeline of PDP-nZEB



Project components

- Component 1 – Project management
- **Component 2 - Analysis of the current state of the building and development of the new nZEB design**
 - Energy audit – in progress (pending cost optimal analysis for energy efficiency measures)
 - Feasibility studies (HVAC system – in development, building digitalization and energy storage system – in process of approval)
 - **Detailed analysis of the structure - seismic analysis (Faculty of Civil Engineering)**
 - Building main design for deep retrofit
- Component 3 – Deep retrofit of an existing public building to achieve the nZEB standard
- Component 4 – Establishment of the National training center for nZEB


Energy audit

About the building

- Office building (5 floors + basement)
- 85 employees
- Usage time: 8-10 hours/day, 5 days/week



Useful heated area	A_k	m^2	2.061
The volume of the heated area	V	m^3	6.998,70
Heated air volume	V_e	m^3	5.670,25
Total area of building envelope	A_f	m^2	2.320,30
Building shape factor	f_0	m^{-1}	0,33



TLOCRT 3. KATA

Energy audit

Thermal characteristics of the building envelope

Index	Surface area (m ²)	U (W/m ² K)	U _{max} (W/m ² K) According to legislation
VZ1 – exterior wall ventilated with glass paneling	400,70	0,37	0,30
VZ1 - external wall ventilated with sheet metal cladding	355,96	0,36	0,30
VZ2 - stone	99,70	0,36	0,30
ST – ceiling towards the unheated attic	395,9	0,29	0,25
SN – ceiling above unheated space	135,62	0,29	0,40
ZN – wall towards unheated space	25,63	0,32	0,40
ZT – wall to ground	130,76	4,08	0,40
PD - floor on the ground	256,15	0,59	0,40
PR1 – windows	461,60	1,43	1,60
PR2 - windows with fixed sunshades	15,20	1,43	1,60
VV – outer doors	29,30	1,43	2,00
VN - doors to unheated space	3,36	1,80	2,00

Energy audit

DISTRICT HEATING SYSTEM

- nominal heat power of the building district heating substation **250 kW** – plate heat exchanger Alfa Laval
- source of thermal energy for space heating and domestic hot water preparation (only for sanitary purposes)
- indirectly heated **hot water storage heater** of nominal capacity **120 L**
- **recirculation line with recirculation pump** (56 W) operating 24 hours/day
- expansion vessel

Indirectly heated hot water storage heater of nominal capacity 120 L



Indirect type of district heating substation in the basement of the nominal heat power 250 kW (manufacture date 2000.)




Expansion vessel



Energy audit

HEATING DISTRIBUTION SUBSYSTEM

- two pipe heating system with lower distribution piping
- **main distributor** in the building substation with **4 heating circuits**:
 - 11** – radiators
 - 22** – heaters of air handling units
 - 33** – fan coils - east
 - 44** – fan coils - west
- fixed speed pumps



Main hot water distributor in the building substation with 4 heating circuits



Vertical exposed and concealed two-pipe fan coil units

Panel radiators in sanitary facilities

HEATING EMISSION SUBSYSTEM

- **81 two-pipe fan coil units** - thermal output **255,99 kW** (45/40°C)
- **14 panel radiators** without thermostatic valves – thermal output **11,20 kW** (90/70°C)

Energy audit

Air-cooled chiller, manufacturer CIAT
 model ILK 400A (build year 2000.)
 cooling capacity 99,6 kW, electrical
 power input 36,1 kW (EER = 2,76)
 Refrigerant R22 → R417A

COOLING GENERATION SUBSYSTEM

- **air-cooled chiller**, manufacturer CIAT model ILK 400A (build year 2000.) cooling capacity 99,6 kW, electrical power input 36,1 kW (EER = 2,76)
 R22 → R417A
- **4 individual air conditioners** (split air conditioners)



4 split air conditioners

Ice bank
 system → 12 m³

Energy audit


COOLING DISTRIBUTION SUBSYSTEM

- main distributor with 3 cooling circuits:
 - 11 – coolers of air handling unit
 - 22 – fan coils - east
 - 33 – fan coils - west
- steel pipes thermally insulated in bad condition → corrosion problems



Main COLD water distributor with 3 cooling circuits

Energy audit



AHU		Manufacturer	Design volume air flow rate – SUPPLY DUCT, [m ³ /h]	Design volume air flow rate – RETURN DUCT, [m ³ /h]	Heat recovery system YES=1, NO=0	Type of heat recovery system	Sensible heat recovery efficiency, [-]	Heating capacity of heating coil [kW]	Cooling capacity of cooling coil [kW]	El. power of supply air fan, [kW]	El. power of exhaust air fan, [kW]	Build year
1	KK Multimedijalna ¹	PROKLIMA	3.500	3.500	1	Cross-flow plate recuperator	0,63 – summer 0,703 winter	38,2	24	1,80	1,20	2000
2	KK Biblioteka	PROKLIMA	1.500	1.500	0	–	–	25	8	1,10	0,55	2000
3	KK Banka	PROKLIMA	1.500	1.500	0	–	–	25	8	1,10	0,55	2000
4	KK Restoran	PROKLIMA	700	700	0	–	–	8,8	5	0,25	–	2000
TOTAL			7.200	7.200	1			97	45	4,25	2,30	

Energy audit

Lighting system

Lighting system power [kW]


Lighting power density [W/m²]

49,54

Target 7



Type	Number	Power [kW]
Halogen lighting	234	12,06
Compact fluorescent lighting with electromagnetic ballast	12	0,46
Compact fluorescent lighting with electronic ballast	318	7,83
Fluorescent lighting with electromagnetic ballast	5	0,25
Fluorescent lighting with electronic ballast	541	28,65
LED lighting	34	0,29
Ukupno	1.144	49,54



- Halogen lighting
- Compact fluorescent lighting with electromagnetic ballast
- Compact fluorescent lighting with electronic ballast
- Fluorescent lighting with electromagnetic ballast
- Fluorescent lighting with electronic ballast
- LED lighting

Energy audit



Other electrical equipment


Power of other electrical equipment [kW]

68,50

Power density of other electrical equipment [W/m²]

33,24


Type	Number	Power [kW]
Office equipment	213	19,47
Kitchen equipment	16	39,43
Servers and IT equipment	33	3,56
Elevator	1	3,60
Other	15	2,44
Ukupno	278	68,50




Energy audit

Energy consumption

Energy	Unit	Baseline values			
		Consumption	Consumption	Costs	CO ₂
		[unit/a]	[kWh/a]	[kn/a]	[t/a]
Electricity	kWh	186.539,00	186.539,00	155.200,23	43,837
District heat	kWh	134.000,00	134.000,00	75.844,35	46,364
Water	m ³	1.051,50	-	27.628,81	0,236
Ukupno			320.539,00	258.673,39	90,437



■ Electricity ■ District heat





■ Electricity ■ District heat ■ Water

Energy audit

Electricity consumption

Total power [kW]	221,53
Total power density [W/m ²]	107,49
Electricity consumption per surface area [kWh/m ²]	90,51
Electricity consumption per employee [kWh/person]	2.194,58




Energy audit

Annual thermal energy consumption: 134.000,00 kWh/a

Annual water consumption: 1.051,50 m³/a

87,63 m³/month



Energy audit

Energy performance certificate




Needed energy for heating $Q''_{H,nd}$ [kWh/(m ² a)]	Needed primary energy E_{prim} [kWh/(m ² a)]	Energy performance rating – energy needed for heating $Q''_{H,nd}$	Energy performance rating – primary energy E_{prim}
38,66	156,14	B	F

- Energy needed for heating: 76.540,66 kWh/a
- Energy needed for cooling: 52.338,59 kWh/a
- Energy needed for DHW: 3.717,95 kWh/a
- Energy needed for lighting: 74.890,31 kWh/a

Energy audit

Consumption measurements


- Electricity for whole building



Energy audit

Consumption measurements

- Lighting system for toilet
- Fan coil
- Printer and photocopier
- Display (monitor)
- Laptop
- Servers






To align the building model with the actual usage



Feasibility studies

- Feasibility study of integration of photovoltaic system, battery system and charging stations for electric vehicles and digitalization of building systems – in process of approval
 - Determining the optimal technology and functionality of the integrated photovoltaic power plant system, stationary battery system and charging stations for electric vehicles
 - Determining the basic preconditions and proposing options for the introduction of a digital system for integrated monitoring and management of individual building systems
- Selection of the optimal software solution for lighting management – drafted
- Selection of the optimal technical solution of the HVAC system in a set of different variants of thermal protection of building envelope and lighting system solutions – drafted

Feasibility studies – PV, battery and digitalization



Feasibility studies – HVAC optimal solution





Energy Institute Hrvoje Požar

Savska cesta 163, Zagreb, Croatia

T: + 385 99 5326 276

mvajdic@eihp.hr

www.eihp.hr